

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. **14763**

Dated: **29-02-2024**

It is certified that an inspection team headed by **Dr. Rajesh Gangwar, A.C.M.O., Amroha**

(Name of Officers with designation) from **Health Department** PHED

inspected the **S.R.S International School, Fawadapur, Gajraula**

(Name & Address of the school) on **29.02.2024** (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. **583/41/2111/31/21.05** dated **26.02.2024**

of **Jal Nigam Lab, Amroha** (PHED Lab) certified that the

S.R.S International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till **one year**

Signature with Seal: 

Name

Designation

Name & Address of the Office / Department : **Amroha**

To **S.R.S International School**
Fawadapur, Gajraula
(Name & Address of the Institution)

A.C.M.O.
Amroha

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 594 / प्रौद्योगिकी / 06

Dated: 27/02/24

It is certified that an inspection team headed by Shahroz Arif, Assistant Engineer,

(Name of Officers with designation) from Jal Nigam Amroha, PHED

inspected the SRS International School, Faundapur, Gajraula,

(Name & Address of the school) on 27/02/24 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 503/प्रौद्योगिकी/05 dated 26/02/24

of Dist. Lab Amroha (PHED Lab) certified that the

SRS International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 01 Year

Signature with Seal: 27/02/24

Name: Shahroz Arif

Designation: AE

Name & Address of the Office / Department: सहायक अभियन्ता

सहायक अभियन्ता
SWSM

To SRS International School
Faundapur, Gajraula, Dist. Amroha (UP)
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



कार्यालय
अधिकासी अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण),
अमरोहा

By E-Mail
E-Mail ID cdupjn_amroha@yahoo.com

पत्रांक 583 / उपयोगशाला अमरोहा 05 दिनांक 26-02-2024

सेवा में,

एस० आर०एस० इंटरनेशनल स्कूल
फौदापुर, गजरौला
अमरोहा

विषय— पानी की जांच के संबंध में।

महोदय,

उपरोक्त विषयक दिनांक 22.02.2024 को आपके द्वारा एस० आर०एस०
इंटरनेशनल स्कूल फौदापुर गजरौला जिला अमरोहा उपलब्ध कराये गये पेयजल
नमूने की जांच खण्डीय प्रयोगशाला में की गयी। जांचोंपरान्त जांच रिपोर्ट संलग्न
कर प्रेषित है।

संलग्नक:— उपरोक्तानुसार।

भवदीय

(चन्द्रहास)

अधिकासी अभियन्ता

पृ०सं० एवं दिनांक उपरोक्तानुसार।

प्रतिलिपि:— सहायक अभियन्ता/जू०इंजी० लैब को सूचनार्थ हेतु प्रेषित।

अधिकासी अभियन्ता

Shekhar
AT Lab
26/2/24



कार्यालय अधिशासी अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम(ग्रामीण), अमरोहा

प्रयोगशाला टैस्टिंग रिपोर्ट

| क्र०सं० | नगर / मोहल्ले का नाम | स्थल का नाम / लोकेशन | श्रोत का नाम | रंग | गंध | गंदलापन (NTU) | टी०डी० एस० | पी०एच० | रासायनिक परीक्षण (पी०पी०एम० में) | | | | |
|---------|----------------------|-----------------------------|--------------|--------|--------|---------------|---------------|---------------|----------------------------------|---------------|-----------------|----|----------|
| | | | | | | | | | क्लोराईड | कुल क्षारीयता | सम्पूर्ण कठोरता | | |
| 1 | 2 | 3 | 4 | 5 | 6 | 7 | Limit 50-2000 | Limit 6.5-8.5 | Limit 250-1000 | Limit 200-600 | Limit 300-600 | 12 | 13 |
| | ग्राम फौदापुर गजरौला | एस. आर. एस. इंटरनेशनल स्कूल | आर०ओ | रंगहीन | गंधहीन | 1.02 | 151 | 7.40 | 50 | 220 | 200 | | संतोषजनक |

Tested by lab Assistant

Approved by Chemist

CHEMIST
Water Testing Laboratory
U.P. Jal Nigam, Amroha